



The City of Burlingame

CITY HALL - 501 PRIMROSE ROAD
BURLINGAME, CALIFORNIA 94010-3997

1740 ROLLINS ROAD AND 842 COWAN ROAD **PUMP STATION UPGRADES** **CITY PROJECT NO. 84820 & 83390**

ADDENDUM NO. 1

June 19, 2019

NOTICE TO ALL PLAN HOLDERS/BIDDERS

This addendum and its attachments shall become a part of the plans and specifications and shall apply to the bid proposals for the above-named project. The bidder(s) shall notify all affected subcontractors, material suppliers, and others to incorporate necessary cost updates, to the bid proposal and the work changes affected by this Addendum.

In the event of conflict between plans and specifications and this addendum, the addendum shall take precedence. Any modifications necessary to incorporate the revisions shall be included in the appropriate bid prices. The bid documents are hereby corrected, modified, and/or amended in the following manner:

Notice is hereby given that the following revisions are made a part of the above Contract Documents:

CONCERNING THE CONTRACT DRAWINGS:

1. On Sheet E3.1, Construction Note 5 is replaced with the following:

“CITY’S INTEGRATOR WILL BE RETAINED BY THE CITY AND SHALL PROVIDE THE REPROGRAMMING OF THE RTU#10 PLC. THE CONTRACTOR SHALL COORDINATE WITH THE CITY TO SCHEDULE THE PROGRAMMER’S SERVICES SUFFICIENTLY IN ADVANCE OF EQUIPMENT START-UP SO AS TO AVOID DELAYS.”

2. On Sheet E3.2, Construction Note 11 is replaced with the following:

“CITY’S INTEGRATOR WILL BE RETAINED BY THE CITY AND SHALL PROVIDE THE REPROGRAMMING OF THE RTU#14 PLC. THE CONTRACTOR SHALL COORDINATE WITH THE CITY TO SCHEDULE THE PROGRAMMER’S SERVICES SUFFICIENTLY IN ADVANCE OF EQUIPMENT START-UP SO AS TO AVOID DELAYS.”

Date: June 19, 2019

Addendum No. 1

1740 ROLLINS AND 842 COWAN ROAD PUMP STATION UPGRADES
CITY PROJECT NO. 84820 & 83390

DELAYS.”

3. On Sheet E3.4, Construction Note 3 is replaced with the following:

“CITY’S INTEGRATOR WILL BE RETAINED BY THE CITY AND SHALL PROVIDE THE REPROGRAMMING OF THE RTU#10 PLC. THE CONTRACTOR SHALL COORDINATE WITH THE CITY TO SCHEDULE THE PROGRAMMER’S SERVICES SUFFICIENTLY IN ADVANCE OF EQUIPMENT START-UP SO AS TO AVOID DELAYS.”

4. On Sheet E6.1, Construction Note 5 is replaced with the following:

“CITY’S INTEGRATOR WILL BE RETAINED BY THE CITY AND SHALL PROVIDE THE REPROGRAMMING OF THE RTU#11 PLC. THE CONTRACTOR SHALL COORDINATE WITH THE CITY TO SCHEDULE THE PROGRAMMER’S SERVICES SUFFICIENTLY IN ADVANCE OF EQUIPMENT START-UP SO AS TO AVOID DELAYS.”

5. On Sheet E6.3, Construction Note 3 is replaced with the following:

“CITY’S INTEGRATOR WILL BE RETAINED BY THE CITY AND SHALL PROVIDE THE REPROGRAMMING OF THE RTU#11 PLC. THE CONTRACTOR SHALL COORDINATE WITH THE CITY TO SCHEDULE THE PROGRAMMER’S SERVICES SUFFICIENTLY IN ADVANCE OF EQUIPMENT START-UP SO AS TO AVOID DELAYS.”

CONCERNING THE TECHNICAL SPECIFICATIONS:

The bid opening date is hereby revised to be **Tuesday, July 16, 2019 at 2:00pm.**

COVER

Revise to read: BIDS WILL BE OPENED AT 2:00 P.M. ON **JULY 16, 2019**

NOTICE INVITING SEALED BIDS

Revised to read: Sealed proposals will be received at the office of the City Clerk, City Hall, 501 Primrose Road, Burlingame, California, until 2:00 P.M., on **Tuesday, July 16, 2019**, and will, at 2:00 P.M. on that date, be publicly opened and read at the City Hall, in Conference Room A for: 1740 ROLLINS ROAD AND 842 COWAN ROAD PUMP STATION UPGRADES, CITY PROJECT NOS. 84820 & 83390, within the City of Burlingame, San Mateo County, California.

Date: June 19, 2019

Addendum No. 1

1740 ROLLINS AND 842 COWAN ROAD PUMP STATION UPGRADES
CITY PROJECT NO. 84820 & 83390

This Addendum consists a total of 3 pages.

All bidders shall acknowledge receipt and acceptance of Addendum No. 1 by signing in the space provided at the end of this Addendum and submitting the signed Addendum with their proposal. Failure to do so may constitute grounds for rejection of the bid.

Regards,

Mahesh Yedluri, P.E.
Senior Civil Engineer

CONTRACTOR SIGNATURE

DATE

COMPANY NAME