



The City of Burlingame

CITY HALL - 501 PRIMROSE ROAD
BURLINGAME, CALIFORNIA 94010-3997

1740 ROLLINS ROAD AND 842 COWAN ROAD **PUMP STATION UPGRADES** **CITY PROJECT NOS. 84820 & 83390**

ADDENDUM NO. 3

July 3, 2019

NOTICE TO ALL PLAN HOLDERS/BIDDERS

This addendum and its attachments shall become a part of the plans and specifications and shall apply to the bid proposals for the above-named project. The bidder(s) shall notify all affected subcontractors, material suppliers, and others to incorporate necessary cost updates, to the bid proposal and the work changes affected by this Addendum.

In the event of conflict between plans and specifications and this addendum, the addendum shall take precedence. Any modifications necessary to incorporate the revisions shall be included in the appropriate bid prices. The bid documents are hereby corrected, modified, and/or amended in the following manner:

Notice is hereby given that the following revisions are made a part of the above Contract Documents:

CONCERNING THE CONTRACT DRAWINGS:

1. Drawing S-3 – 1740 Rollins Road Pump Stations Proposed Site Plan

The following sentence is added to Note 6:

The Contractor shall be required to apply for and obtain the necessary underground fuel tank removal fire permits from the Central County Fire Department and the San Mateo County Environment Health division prior to conducting the fuel tank and underground fuel line removal work.

2. Drawing S-5 – 842 Cowan Road Pump Station Proposed Site Plan

The following sentence is added to Note 9:

The Contractor shall be required to apply for and obtain the necessary underground fuel

Date: July 3, 2019

Addendum No. 3

**1740 ROLLINS AND 842 COWAN ROAD PUMP STATION UPGRADES
CITY PROJECT NOS. 84820 & 83390**

tank removal fire permits from the Central County Fire Department and the San Mateo County Environmental Health division prior to conducting the fuel tank and underground fuel line removal work.

3. Drawing E1.0 – 1740 Rollins Road Pump Station Single Line Diagram

The following sentence is added to Note 7:

The Contractor shall be required to coordinate and complete a fuel tank pressure test and also demonstrate all system safety devices and alarms as described under Technical Specification Section 26_32_14.1, Paragraph 3.3 H, in the presence of a Central County Fire Department representative as a condition of obtaining system acceptance of the standby generator.

4. Drawing E4.0 – 842 Cowan Road Pump Station Single Line Diagram

The following sentence is added to Note 5:

The Contractor shall be required to coordinate and complete a fuel tank pressure test and also demonstrate all system safety devices and alarms as described under Technical Specification Section 26_32_14.2, Paragraph 3.3 H, in the presence of a Central County Fire Department representative as a condition of obtaining system acceptance of the standby generator.

CONCERNING THE TECHNICAL SPECIFICATIONS:

1. Page 26_32_14.1-27, Section 26_32_14.1 – Diesel Generator Sets (1740 Rollins Road Pump Station), Part 3.3 On-Site Acceptance Test

The following Paragraph I is added to Part 3.3:

I. Coordinate and conduct a witnessed pressure test of the generator fuel tank in the presence of a Central County Fire Department representative as a condition of obtaining system acceptance of the standby generator.

2. Page 26_32_14.2-25, Section 26_32_14.2 – Diesel Generator Sets (842 Cowan Road Pump Station), Part 3.3 On-Site Acceptance Test

The following Paragraph I is added to Part 3.3:

I. Coordinate and conduct a witnessed pressure test of the generator fuel tank in the presence of a Central County Fire Department representative as a condition of obtaining system acceptance of the standby generator.

Date: July 3, 2019

Addendum No. 3

1740 ROLLINS AND 842 COWAN ROAD PUMP STATION UPGRADES
CITY PROJECT NOS. 84820 & 83390

This Addendum consists a total of 3 pages.

All bidders shall acknowledge receipt and acceptance of Addendum No. 3 by signing in the space provided at the end of this Addendum and submitting the signed Addendum with their proposal. Failure to do so may constitute grounds for rejection of the bid.

Very truly yours,

Mahesh Yedluri, P.E.
Senior Civil Engineer

CONTRACTOR SIGNATURE

DATE

COMPANY NAME