



NOTE:

1. IF CURB FACE IS LESS THAN THE STANDARD 6" DEPTH AND THE MINIMUM COVER OF 2.5" CANNOT BE ATTAINED, DO ONE OR MORE OF THE FOLLOWING:
 - (A) CHANGE TO AN OVAL PIPE;
 - (B) INSTALL MULTIPLE SMALLER DIA. PIPES;
 - (C) INSTALL A #3 REBAR OVER THE PIPE IN THE CURB FACE AREA.
2. ALL CONCRETE SHALL BE CLASS B (5 SACK MIX), 3/4" MAX. AGGREGATE, WITH 2LB.-LAMPBLACK PER CUBIC YARD ADDED FOR COLORATION.
3. ALL CONCRETE SHALL HAVE A LIGHT BROOMED FINISH, COLORED AND SCORED TO MATCH SURROUNDING SIDEWALK. SEE SIDEWALK DETAIL DRAWING A-1699.



STANDARD CURB DRAIN

DEPARTMENT OF PUBLIC WORKS

APPROVED BY

DATE
08/29/2006

DRAWING NO.

SW-2